



**SHLOKA  
A Birla School**

### **FIRE SAFETY CERTIFICATE**

**SELF CERTIFIED AS PER GOVERNMENT NOTIFICATION: GH/V/9 OF 2021/AGN-102021-100 L-1 DT 22 JANUARY 2021 & SUBSEQUENT CIRCULAR FROM THE DIRECTOR, STATE FIRE PREVENTION SERVICES, GANDHINAGAR NO SFS/FN-85.1/149/2021 DATED 5<sup>TH</sup> JUNE 2021**

We hereby declare that our school building is situated at Salvav village, valsad.

We hereby declare that our school building is only of ground floor without basement and its height is only 5 meters which is below 9 meters. So Fire NOC is not required as per Gujarat State Government Rules of Urban Development and Urban Housing Department. Further a clarification of the same was issued from the office of the Director, State Fire Prevention Services, Gandhinagar No SFS/FN-85.1/149/2021 dated 5<sup>th</sup> June 2021 on the same subject that educational building which are below the height of 9 meters do not require fire NOC.

As per the requirement for fire prevention stated by the State Fire Prevention Services the school has followed all precautions.

Fire extinguishers 12 numbers and 2 fire buckets have been installed at all the key points of the school.

Principal

26-07-2023

Salvav

Copy to :

1. District Education officer, Valsad
2. Regional Fire office, Kamrej, Surat

  
**NASIM LAIK AHMAD SHAIKH**  
**MANAGING TRUSTEE**  
**PRAYAS FOUNDATION TRUST, VAPI**

  
**PRINCIPAL**  
**SHLOKA A BIRLA SCHOOL**  
**SALVAV, VAPI**



ISO 17100:2015 Number- UQ-2022121981  
Government Certification No - NSIC/GP/SUR/2019/0039812



ISO 17100:2015 & Govt. Reg. Company

Date: 21<sup>th</sup> July - 2023  
Sr. No - 19695-2023-24

**TO WHOMSOEVER IT MAY CONCERN**

We, M/s EUROPEAN HOUSE, are an ISO 17100:2015 registered company for Language Translation and Interpretation services under the Certificate No. ISO 17100:2015 Number-UQ-2022121981&NSIC/GP/SUR/2019/0039812.

The Document -“**CLARIFICATION REGARDING ISSUANCE OF FIRE SAFETY CERTIFICATE**” translated from Gujarati Language to English Language (True Translation) by “EUROPEAN HOUSE” On request from PRINCIPAL SHLOKA A BIRLA SCHOOL,VAPI.

Name of the Authorized Signatory: Vikash Jha

Stamp/ Signature:



209, 2<sup>nd</sup> Floor, Kamla Park Complex, Tarsali, Vadodara -390009, Gujarat (India)  
M: 9016527086 / 9723815238 Email: info@intraword.com web: www.intraword.com

  
**PRINCIPAL**  
**SHLOKA A BIRLA SCHOOL**  
**SALVAV, VAPI**

  
**NASIM LAIK AHMAD SHAIKH**  
**MANAGING TRUSTEE**  
**DDAVS FOUNDATION TRUST, VAPI**

**WE SERVE TO SAVE**

Office of State Fire Prevention Services

Block No. 13, 3rd Floor, Dr. Jivaraj Mehta Bhavan, Gandhinagar – 382010.

E-mail: [dir.sfps@gmail.com](mailto:dir.sfps@gmail.com), Telephone No. 079-232-57022/23/40.

LOGO

Satyameva Jayate

No: SFS/FN - 85.1/149/2021

Date - 05/06/2021

Subject: Clarification regarding issuance of Fire Safety Certificate

**CIRCULAR:-**

The Government has made the provision for the issuance of Fire Safety Certificate (Fire NOC) as per the provision of Rule - 23(1) for buildings as per Third Schedule of Gujarat Fire Prevention and Life Safety Measures (Amendment) Rules, 2021. From time to time some difficulties are experienced in the issuance of Fire NOC during field level operations, during meetings with Regional Fire Officer/Chief Fire Officer of the State. So it becomes necessary to clarify this matter.

In the case of an Educational institutions which are less than 9 meters in height and/or 500 sq.mts floor area of any one or more floors as mentioned in the Third Schedule of Gujarat Fire Prevention and Life Safety Measures (Amendment) Rules, 2021, regarding the provision of obtaining the Fire Safety Certificate by the Educational institution, it should be clarified that a Fire Safety Certificate is required to be obtained from the Concerned Fire Authority as per the rules only in the case of an Educational institution having a height of 9 meters or more and if it has a basement whose area is more than 200 Sq. mts. In cases other than this, in which the height of the Educational institution is less than 9 meters, apart from considering the floor area, the administrator of such Educational institution has to send a certificate i.e. self-certification to the approving authority that the necessary arrangements regarding fire safety have been made by the educational institution. For all types of educational institutions with a height of less than 9 (nine) meters, the administrator of the educational institution has to make arrangements as per the checklist attached herewith and send the certificate to the approving authority of the educational institution.



*N.L.S.*  
**NASIM LAIK AHMAD SHAIKH**  
**MANAGING TRUSTEE**  
**PRAYAS FOUNDATION TRUST, VAPI**

*[Signature]*  
**PRINCIPAL**  
**SHLOKA A BIRLA SCHOOL**  
**SALVAV, VAPI**

In every district the Inspector of the Education Department or other Authorized Officer also has to supervise as per this checklist from time to time.

SIGNATURE

Director  
State Fire Prevention Services,  
Gandhinagar.

Copies sent to -

1. Additional Chief Secretary, Urban Development and Urban Housing Department, Gandhinagar.
2. Principal Secretary, Education Department, Gandhinagar.
3. Secretary, Education Department, Gandhinagar.
4. Commissioner ate of Higher Education, Gandhinagar.
5. Commissioner ate (Educational Institution), Gandhinagar.
6. Directorate of Primary Education, Gandhinagar.
7. Directorate, Office of Technical Education, Gandhinagar.
8. Commissioner, Office of Municipal Administration, Gandhinagar.
9. Commissioner, Municipal Corporation - Ahmedabad, Gandhinagar, Surat, Vadodara, Rajkot, Jamnagar, Junagadh, Bhavnagar.
10. Regional Municipal Commissioner, Ahmedabad, Gandhinagar, Bhavnagar, Surat, Vadodara, Rajkot.

Copies Sent:-

1. All District Education Officers
2. Regional Fire Officer, Vadodara, Gandhidham, Rajkot, Gandhinagar, Surat
3. Chief Fire Officer, Municipal Corporation - Ahmedabad, Gandhinagar, Surat, Vadodara, Rajkot, Jamnagar, Junagadh, Bhavnagar.



A handwritten signature in blue ink, appearing to read "Nasim Laik Ahmad Shaikh".

NASIM LAIK AHMAD SHAIKH  
MANAGING TRUSTEE  
PRAYAS FOUNDATION TRUST, VAPI

A handwritten signature in blue ink, appearing to read "Shloka A Birla".

PRINCIPAL  
SHLOKA A BIRLA SCHOOL  
SALVAV, VAPI

CHECKLIST

Regarding provision of minimum fire safety in buildings of educational institutions having a height of 9 meters or less than 9 meters

1. Educational buildings which have only ground floor

Sr. No	TYPE OF FIRE PROTECTION	REQUIREMENT
1	FIRE EXTINGUISHER	Two Units. per floor (each in 1000 sq.m.) In Which 1- 4.5 k.g. Type Co <sub>2</sub> Fire Extinguishers, 2- 6 k.g. ABC Type Fire Extinguishers

2. Educational buildings having only ground floor + first floor and ground + first + second floor which are less than 9 meters in height.

Sr. No	TYPE OF FIRE PROTECTION	REQUIREMENT
1	FIRE EXTINGUISHER	Two Units. per floor (each in 1000 sq.m.) In Which 1- 4.5 k.g. Type Co <sub>2</sub> Fire Extinguishers, 2- 6 k.g. ABC Type Fire Extinguishers
2	HOSE- REEL HOSE ASSEMBLY	On each floor at an area of 1000 sq.mts
3	WATER TANK (TERRACE LEVEL)	10000 Liters
4	FIRE PUMP (TERRACE LEVEL)	Electric pump of 450 L.P.M capacity



True Translation of Original - Source language - Gujarati  
Certificate Number - UQ-2022121981 Target language - English  
Translated and Certified by - EH Translation Services

**NASIM LAIK AHMAD SHAIKH**  
**MANAGING TRUSTEE**  
**PRAYAS FOUNDATION TRUST, VAPI**

**PRINCIPAL**  
**SHLOKA A BIRLA SCHOOL**  
**SALVAV, VAPI**



સત્યમેવ જયતે

WE SERVE TO SAVE

રાજ્ય અગ્નિ નિવારણ સેવાઓની કચેરી

બ્લોક નં.૧૩, ત્રીજો માળ, ડૉ.જીવરાજ મહેતા ભવન, ગાંધીનગર-૩૮૨૦૧૦.

ઈ-મેલ: [dir.sfps@gmail.com](mailto:dir.sfps@gmail.com), ટેલિફોન નં.૦૭૯-૨૩૨-૫૭૦૨૨/૨૩/૪૦.

ક્રમાંક: સફસ/ફન- ૮૫.૧/૨૩૮/૨૦૨૧

તા.૦૫/૦૬/૨૦૨૧


વિષય:- ફાયર સેફ્ટી સર્ટિફિકેટ ઈશ્યુ કરવા બાબત સ્પષ્ટતા થવા બાબત.

પરિપત્ર:-

સરકારશ્રી દ્વારા ગુજરાત અગ્નિ નિવારણ અને જીવન સુરક્ષા ઉપાય વિષયક (સુધારા) નિયમો, ૨૦૨૧ ની ત્રીજી અનુસૂચિ મુજબનાં બિલ્ડીંગો માટે નિયમ -૨૩(૧) ની જોગવાઈ મુજબ ફાયર સેફ્ટી સર્ટિફિકેટ (ફાયર NOC) ઈશ્યુ કરવાની જોગવાઈ થયેલી છે. વખતોવખત રાજ્યના રીજીયનલ ફાયર ઓફીસર/ચીફ ફાયર ઓફીસર સાથે મીટીંગો દરમ્યાન ક્ષેત્રિક કક્ષાએ કામગીરી દરમ્યાન ફાયર NOC ઈશ્યુ કરવા મામલે અમૂક મુશ્કેલીઓ અનુભવાય છે. જેથી આ બાબતે સ્પષ્ટતા કરવી જરૂરી બને છે.

શૈક્ષણિક સંસ્થાઓનાં કિસ્સામાં જે ગુજરાત અગ્નિ નિવારણ અને જીવન સુરક્ષા ઉપાય વિષયક(સુધારા) નિયમો, ૨૦૨૧ ની ત્રીજી અનુસૂચીમાં જણાવ્યાનુસાર ૯ મી ઉંચાઈ અને/ અથવા ૫૦૦ચો.મી. કોઈ એક કે વધુ માળનાં ક્ષેત્રફળથી ઓછાં ઉંચાઈ/ક્ષેત્રફળનાં કિસ્સામાં શૈક્ષણિક સંસ્થા દ્વારા ફાયર સેફ્ટી સર્ટિફિકેટ લેવાની જોગવાઈ સંદર્ભે વિશેષ સ્પષ્ટતા કરતા જણાવવાનું કે, જે શૈક્ષણિક સંસ્થા ૯ મીટર કે તેથી વધુ ઉંચાઈ ધરાવતી હોય તેમજ એમા જો બેઝમેન્ટ હોય તો એનું ક્ષેત્રફળ ૨૦૦ ચો.મીથી વધુ હોય તેવા કિસ્સામાં જ સંબંધિત ફાયર અધિકારી પાસેથી જ ફાયર સેફ્ટી સર્ટિફિકેટ નિયમોનુસાર મેળવવાનું રહે છે. આ સિવાયના કિસ્સાઓમાં કે જેમાં શૈક્ષણિક સંસ્થા કે જેની ઉંચાઈ ૯ મીટરથી ઓછી હોય તેવા કિસ્સામાં ફ્લોર એરિયા ધ્યાને લીધા સિવાય એવી શૈક્ષણિક સંસ્થાનાં સંચાલકે ફાયર સેફ્ટી અંગેની જરૂરી વ્યવસ્થા શૈક્ષણિક સંસ્થા દ્વારા કરી એ મતલબનું સેલ્ફ સર્ટિફિકેશન કરી એવું સર્ટિફિકેટ મંજૂરી આપનાર ઓથોરિટીને મોકલી આપવાનું રહેશે. આ ૯ (નવ) મીટરથી ઓછી ઉંચાઈ વાળી તમામ પ્રકારની શૈક્ષણિક સંસ્થાઓ માટે આ સાથે સામેલ ચેક લીસ્ટ મુજબની વ્યવસ્થા કરી શૈક્ષણિક સંસ્થાનાં સંચાલકે પ્રમાણપત્ર સહ શૈક્ષણિક સંસ્થાને મંજૂરી આપનાર

ઓથોરીટીને મોકલી આપવાની રહે છે. દરેક જીલ્લામાં શિક્ષણ વિભાગનાં નિરિક્ષકશ્રી કે અન્ય અધિકૃત અધિકારી દ્વારા પણ આ ચેક લીસ્ટ મુજબ વખતો-વખત ચકાસણી કરવાની રહેશે.



નિયામક

રાજ્ય અગ્નિ નિવારણ સેવાઓ,  
ગાંધીનગર.

નકલ સવિનય રવાના-

1. અધિક મુખ્ય સચિવશ્રી, શહેરી વિકાસ અને શહેરી ગૃહ નિર્માણ વિભાગ, ગાંધીનગર.
2. અગ્ર સચિવશ્રી, શિક્ષણ વિભાગ, ગાંધીનગર.
3. સચિવશ્રી, શિક્ષણ વિભાગ, ગાંધીનગર.
4. ઉચ્ચ શિક્ષણ કમિશ્નરશ્રી, ગાંધીનગર.
5. કમિશ્નરશ્રી(શૈક્ષણિક સંસ્થાઓ), ગાંધીનગર.
6. પ્રાથમિક શિક્ષણ નિયામકશ્રી, ગાંધીનગર.
7. નિયામકશ્રી, ટેકનિકલ શિક્ષણની કચેરી, ગાંધીનગર.
8. કમિશ્નરશ્રી, મ્યુનિસિપાલીટીઝ એડમીનીસ્ટ્રેશનની કચેરી, ગાંધીનગર.
9. કમિશ્નરશ્રી, મહાનગરપાલીકા- અમદાવાદ, ગાંધીનગર, સુરત, વડોદરા, રાજકોટ, જામનગર, જુનાગઢ, ભાવનગર.
10. રીજીયોનલ મ્યુનિસિપલ કમિશ્નરશ્રી, અમદાવાદ, ગાંધીનગર, ભાવનગર, સુરત, વડોદરા, રાજકોટ.

નકલ રવાના:-

1. જિલ્લા શિક્ષણ અધિકારીશ્રી, તમામ.
2. રીજીયોનલ ફાયર ઓફિસરશ્રી, વડોદરા, ગાંધીધામ, રાજકોટ, ગાંધીનગર, સુરત.
3. ચીફ ફાયર ઓફિસરશ્રી, મહાનગરપાલિકા- અમદાવાદ, ગાંધીનગર, સુરત, વડોદરા, રાજકોટ, જામનગર, જુનાગઢ, ભાવનગર.

ચેક લીસ્ટ

૯ મીટર કે ૯ મીટર કરતા ઓછી ઉંચાઈ ધરાવતી શૈક્ષણિક સંસ્થાઓ ની  
ઈમારતોમાં લઘુત્તમ ફાયર સેફ્ટીની સુવિધા કરવા બાબત.

૧. જે માત્ર ગ્રાઉન્ડ ફ્લોર ધરાવતી શૈક્ષણિક ઈમારતો

ક્રમ નં	ટાઈપ ઓફ ફાયર પ્રોટેક્શન	જરૂરીયાત
૧	ફાયર એક્સ્ટિંગ્વિશર	દરેક માળ ઉપર બે નંગ(દરેક ૧૦૦૦ ચો.મી.માં) જેમાં ૧ - 4.5 k.g. Type Co <sub>2</sub> Fire Extinguishers, ૨ - 6 k.g. ABC Type Fire Extinguishers

૨. જે માત્ર ૯ મીટરથી ઓછી ઉંચાઈ ધરાવતી હોય તેવી ગ્રાઉન્ડ ફ્લોર + પ્રથમ માળ અને  
ગ્રાઉન્ડ + પ્રથમ + બીજો માળ ધરાવતી શૈક્ષણિક ઈમારતો.

ક્રમ નં	ટાઈપ ઓફ ફાયર પ્રોટેક્શન	જરૂરીયાત
૧	ફાયર એક્સ્ટિંગ્વિશર	દરેક માળ ઉપર બે નંગ(દરેક ૧૦૦૦ ચો.મી.માં) જેમાં ૧ - 4.5 k.g. Type Co <sub>2</sub> Fire Extinguishers, ૨ - 6 k.g. ABC Type Fire Extinguishers
૨	હોઝ-રીલ હોઝ એસમ્બલી	દરેક માળે ૧૦૦૦ ચો.મી. વિસ્તારે એક પ્રમાણે
૩	પાણીની ટાંકી(ટેરેસ લેવલ)	૧૦૦૦૦ લિટર
૪	ફાયર પમ્પ(ટેરેસ લેવલ)	૪૫૦ એલ.પી.એમ. કેપેસિટી નો ઇલેક્ટ્રિક પમ્પ