

Copy of the Water, Health and Sanitation Certificate issued by Chief District Health Officer, Valsad

No. D.P./ Sanitation/Certificate/D.S.I.W.S/ 526 /2025
District Panchayat, Health Branch, Valsad
Date:- 03 /06/2025

To,
The Principal,
SHLOKA A BIRLA SCHOOL
At-Salvav,
Ta.Vapi, Dist-Valsad

Sub:- To issue Certificate of safe drinking water and Sanitary condition

Ref:- Your application Dt.23/05/2025

With reference to you letter dated above the required certificate is attached Here with.


Chief District Health Officer
District Panchayat, Valsad for

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Chief District Health Officer from District Panchayat, Valsad inspected the SHLOKA A BIRLA SCHOOL, At-Salvav, Ta.Vapi, Dist-Valsad -396191 (Gujarat) India on 29/05/2025 and on the basic of Water Test Report bearing no. AE/LAB-B/05/25/187 dated 17/05/2025 of ADITYA ENVIRON (PHED Lab) certified that the the SHLOKA A BIRLA SCHOOL, SALVAV has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State/ U.T. Govt.

This certificate is valid till 31/12/2025




Chief District Health Officer
District Panchayat, Valsad


PRINCIPAL
SHLOKA A BIRLA SCHOOL
SALVAV, VAPI


NASIM LAIK AHMAD SHAIKH
MANAGING TRUSTEE
PRAYAS FOUNDATION TRUST, VAPI

Copy of the Water Examination Report

ADITYA ENVIRON

GPCB approved schedule II auditor & ISO 17025 : 2017 NABL Accredited
ISO 9001:2015 certified



Office 1 : Plot No. 190, 4th Floor, Aum Auto Hub, Vibrant Business Park, Opp. UPL Company Ltd., GIDC, Vapi - 396195. Tal – Vapi, Dist –Valsad, Gujarat.
Mobile : +91 99250 44987, +91 91737 93913 | E-mail: sejal@adityainfra.com, sejalmapate145@gmail.com | Web: www.adityaenviron.com

ISO/IEC 17025:2017 NABL Accredited Company	Gujarat Pollution Control Board (Govt. of Gujarat) Authorized Environmental Auditor (Schedule -II)	ISO 9001: 2015 Certified Company
--	--	----------------------------------

TEST REPORT

Sample ID.No. (LAB)	AE/LAB-B/05/25/187	Issue Date	17/05/2025
Customer's Name & Address	Shloka A Birla School Salvav, Rata Road opposite Big Bazaar, Vapi, Gujarat 396191.	Environmental Condition:	25±5°C

Description of Sample	Drinking Water	Qty./No. of Samples	2.0 Lit.
Sampling Date	14/05/2025	Sample Received Date	14/05/2025
Date of Starting of Test	14/05/2025	Date of Completion of Test	17/05/2025
Appearance of Sample	Colourless Liquid	Sampling Procedure	Grab

RESULT TABLE

Sr. No.	Parameters	Test Method Permissible	Results	Standard Limit
Physical Quality				
1	pH @ 25 ° C	IS 3025 (Part 11):2022	7.48	6.5-8.5
2	Colour	IS 3025 (Part 4):2021	Below 1	NMT 5
3	Odour	IS 3025 (Part 5):2018	Agreeable	Agreeable
4	Taste	IS 3025 (Part 8):2023	Agreeable	Agreeable
5	Turbidity	IS 3025 (Part 10):2023	0.18	1 NTU
Chemical Quality (In mg/l)				
6	Residual Free Chlorine	IS 3025 (Part 26) : 2021	BDL	NMT 0.2
7	Chloride as Cl-	IS 3025 (Part 32):2019	54.59	NMT 250
8	Total Hardness	IS 3025 (Part 21):2019	50.00	NMT 200
9	Calcium as Ca	IS 3025 (Part 40):2019	ND	NMT 75
10	Magnesium as Mg ⁺⁺	IS 3025 (Part 46):2023	ND	NMT 30
11	Total Dissolved Solids	IS 3025 (Part 16):2023	160.00	NMT 500
12	Total Suspended Solids	IS 3025(Part 17)	6.00	NMT 5
13	Sulphate as SO ₄ -2	IS 3025 (Part 24):2022	20.82	NMT 200
14	Iron as Fe	IS 3025 (Part 53):2019	ND	NMT 0.3
15	Chemical Oxygen Demand	IS 3025 (Part 58):2023	18.08	NMT 250
16	Biochemical Oxygen Demand	IS 3025(Part 44):2019	5.31	NMT100

BDL: Below Detection Limit ND: Not Detected

Note: This report is subject to terms & conditions mentioned overleaf

End of Report

Authorized Signatory

Office 2 : 607, MauryanshElanza, Shyamal Cross Road, Satellite, Ahmedabad-380015

PRINCIPAL
SHLOKA A BIRLA SCHOOL
SALVAV, VAPI

NASIM LAIK AHMAD SHAIKH
MANAGING TRUSTEE
PRAYAS FOUNDATION TRUST, VAPI